



Imperial College London

WARWICK



FETS RFQ + MEBT Cooling

21st February 2012





Section 7

Section 2

Section 3

Section



Science & Technology 🐼 SIS

Facilities Council

The RFQ is made up from 4 x 1m long sections that for the purposes of cooling can be considered to be identical.

WARWICK

Imperial College London

Therefore, let's consider the cooling of just one RFQ section.....



Cooling for one RFQ section

Minor vane

Major vane

A one metre RFQ section is made from 2 major vanes (shown in brown) and 2 minor vanes (shown in yellow).

Each major vane is identical and each minor vane is identical. So now we can just consider the cooling requirements of:

•A major vane •A minor vane

Both major and minor vanes are made from C10100 oxygen free copper.



Cooling a FETS RFQ major vane



Cooling for one major vane





A major vane cooling pocket



2 pockets per major vane.

Water flows along square channel (of approx.10mm square) created by baffles. (not 5mm as shown in calculation at the bottom). Inlet and outlet: OD = 12mm, wall = 1mm, ID = 10mm Sample calculation from Scott

Square Cross-Section Milled Main Flow Channel:

Hydraulic diameter of 5 mm square pipe is same as circular pipe $\therefore D_{H} = 5$ mm. For constant mass flow rate in all sections, \rightarrow expected flow velocity ≈ 2.4 m/s. For total milled length = 0.5 m, this gives: $\Delta p \approx 0.09$ Bar $R_{e} \approx 13,000$ HTC $\sim 11,500$ W m⁻² K⁻¹ m \rightarrow

D





The major vane vacuum port

1 vacuum port per major vane. Flow enters by 21mm ID inlet of manifold. Flow divided into 5 x 8mm ID x 260mm long. Flow exits via identical manifold on opposite side.



Inlet and outlet: OD = 25mm Wall = 2mm ID = 21mm

Manifold is made from stainless steel.



Cooling a FETS RFQ minor vane



Minor vane cooling pockets



3 identical pockets per minor vane.

Water flows along square channel (of approx.10mm square) created by baffles. Flow length shorter than for major vane (perhaps 350mm versus 500mm – TBC) Inlet and outlet: OD = 12mm, wall = 1mm, ID = 10mm

Cooling zones

Each 1m RFQ section should be divided into separate cooling zones that can be flow / temperature controlled.

A typical division of zones might be:

Science & Technology

1. Major vane - upper

Facilities Council

- 2. Major vane lower
- 3. Minor vane left
- 4. Minor vane right
- 5. Major vane upper tuners
- 6. Major vane lower tuners



Imperial College London

WARWICK

Zone	Features	Inlets	Outlets
1	2 pockets 1 vac port	2 x 12mm OD, wall 1mm 1 x 25mm OD, wall 2mm	2 x 12mm OD, wall 1mm 1 x 25mm OD, wall 2mm
2	2 pockets 1 vac port	2 x 12mm OD, wall 1mm 1 x 25mm OD, wall 2mm	2 x 12mm OD, wall 1mm 1 x 25mm OD, wall 2mm
3	3 pockets	3 x 12mm OD, wall 1mm	3 x 12mm OD, wall 1mm
4	3 pockets	3 x 12mm OD, wall 1mm	3 x 12mm OD, wall 1mm
5	8 tuners	8 x 10mm OD, wall 1.5mm	8 x 10mm OD, wall 1.5mm
6	8 tuners	8 x 10mm OD, wall 1.5mm	8 x 10mm OD, wall 1.5mm



Cooling zone 1



3 inlets 3 outlets

For tube sizes see table on slide 11





Cooling zone 3





For tube sizes see table on slide 11











ALT I I

Cooling zone 6

Tuners – bottom 8 off



For tube sizes see table on slide 11

Far side tuners not shown for clarity.





Some additional cooled RFQ features





RFQ end flanges



At either end of the RFQ is an end flange assembly. It is cooled via water flowing into a circular channel that can be considered to be 10mm square with a length of 450mm. The assembly is made from copper with diameter 10mm OD, wall 1.5mm, 7mm ID stainless steel input and output tubes.



RFQ couplers

0

The reference design is to have 2 couplers for the 4m long RFQ. There is an option to extend this to 4 couplers if required.

Each coupler is cooled at its tip by a 4mm OD, 0.5mm wall, 3mm ID copper pipe (if that exists).



Possible flow control items





Cooling for one RFQ section



	ZS-40-K	Taptite screw for PF3W704/720 (3 x 10), 4 pcs.
Bracket *	ZS-40-L	Taptite screw for PF3W740 (3 x 10), 4 pcs.
	ZS-40-M	Taptite screw for PF3W711 (4 x 10), 4 pcs.
Lead wire with M8 connector	ZS-40-A	Lead wire length: 3 m

*: 2 brackets are necessary if using the type with flow rate adjustment valve.

Replacement part

2	<u> </u>		
	Element	Part number	Remarks
	PVC tube	ZS-40-U25	25A PVC tube 1 pc.
	25A Holding plate	ZS-40-U25-A	1 pc., With two hexagon socket head cap screws of M5 x 80.
j	Annual state of the second	A dealer and a sead	

*: Accuracy may vary by 1 to 2%, if PVC tube is replaced.



No.PF##-OMM0005-A

Duncan has supplied me with a copy of the SMC manual – note flow switch option with built in control valve for neat close packaging.





Calculating flow rates.....

Flow rates are easy to calculate, if you know how much heat you need to remove and the maximum allowable temperature rise......

$Q=MC_{p}\Delta T$

Where Q = heat load in kW M = mass flow rate (can be taken as volume flow rate in l/s) C_p = specific heat capacity of water 4.18 kJ/kg/K * ΔT = temperature rise

So for the entire RFQ with a heat load to remove of 75kW and a maximum temperature rise of 1K we get a flow rate of 18 l/s or 4.5 l/s for each 1m long RFQ section.

Duncan Couchman, RAL

* This means it takes 4.18 joules of energy to raise 1 gram of water by 1 degree Celsius

HOW EFFECTIVE IS THE COOLING FLOW AROUND ONE MINOR VANE POCKET?

Imperial College

London

WARWICK

We have a flow rate m of 4.5 l/s per 1m RFQ section. Assume that each RFQ section is divided into 6 equal zones, giving 4.5/6 = 0.77 l/s per zone Consider, as an example, the minor vane with 3 identical pockets, each pocket has a flow of 0.77/3 = 0.26 l/s per pocket

Calculating the flow velocity C per minor vane pocket:

Facilities Council

using, $m = \rho A C$ where, m = mass flow rate (kg/s or l/s for water) $\rho = density of water = 1000 kg / m^3$ $A = cross-sectional area of flow (m^2)$ $C = m / \rho A$ $C = 0.26 / (1000) x (1x10^{-4})$ Flow velocity per minor vane pocket = 2.6 m/s

What is the Reynolds number (or, how effective is that flow velocity at cooling)?

Science & Technology

Assume water channel created by baffles is 10mm x 10mm

Using, $Re = \rho v d/\mu$

where, $\begin{aligned} \rho &= \text{density of water} = 1000 \text{ kg / m}^3 \\ v &= 2.6 \text{ m/s} \\ d &= 10\text{mm} = 0.01 \text{ m} \\ \mu &= \text{dynamic viscosity} = 1 \text{ x } 10^{-3} \text{ N.s/m}^2 \text{ (for water at } 20^{\circ}\text{C)} \end{aligned}$ (think honey kept in fridge versus room temp.)

Re = 26,000 too high if flow rate isn't reduced.

- 1. The Reynolds number should be greater than 4,000 for lines actively involved in cooling to ensure that there is turbulent flow within the circuits and hence efficient cooling.
- 2. The ideal Reynolds number to achieve is 10,000.
- 3. Do not aim for a Reynolds number that is greater than 10,000

Therefore, lets see the result of reducing the flow rate from 0.26 l/s to 0.1 l/s

Now, C = 1 m/s Re = 10,000

Spot on!



What is the Heat Transfer Coefficient of this pocket?

We have the Reynold's number so we first need the Prandtl number to calculate the Nusselt number:

 $P_R = C_p \mu/k$

The Prandtl Number is a dimensionless parameter of a convecting system that characterises the regime of convection. It approximates the ratio of momentum diffusivity and thermal diffusivity:

P_R = v / a

 μ = absolute or dynamic viscosity (kg/m s) = 1x 10⁻³ c_p = specific heat capacity (J/kg K) = 4.18 x 10³

 \vec{k} = thermal conductivity (W/m K) = 0.6 for water

 $P_{R} = (4.18 \times 10^{3}) \times (1 \times 10^{-3}) / 0.6 = 7$

or

$$R_{e} = \frac{\rho v D_{H}}{\mu} \implies N_{u} = 0.023 R_{e}^{0.8} P_{R}^{0.4} \qquad \qquad P_{R} = \frac{c_{p} \mu}{k}$$

$$HTC = \frac{N_{u} k}{D_{H}}$$

Nusselt Number: Dittus-Boelter equation

The Dittus-Boelter equation (for turbulent flow) is an explicit function for calculating the Nusselt number. It is easy to solve but is less accurate when there is a large temperature difference across the fluid. It is tailored to smooth tubes, so use for rough tubes (most commercial applications) is cautioned. The Dittus-Boelter equation is:

 $Nu = 0.023 (10000)^{0.8} (7)^{0.4} = 80$

$$N_{\rm D} = 0.023 \ {\rm R_e}^{0.8} \ {\rm P_R}^{\rm n}$$

where:

where:

n = 0.4 for heating of the fluid and n = 0.3 for cooling of the fluid. The Dittus-Boelter equation is valid for:

$0.6 < P_R < 160$	YES
R _e ~ 10,000	YES
L/D > 10	YES

Nusselt number:

Given two parallel plates at different temperatures, the Nusselt number gives the ratio of actual heat transferred between the plates by a moving fluid to the heat transfer that would occur by conduction.

now:

Finally we can calculate the heat transfer coefficient:

 $h = 80 \times 0.6 / 0.010$ = 4800 W/m² K h = 0.0048 W/mm²

(a practical maximum is 0.6 W/mm²)



Extra.....



Circuits:

- De-min circuit in place.
- New low delta T circuit to follow existing needs to be insulated.
- Low delta T circuit for accelerating structures only RFQ and MEBT Cavities.
- •Remainder of FETS line can be on existing de-min circuit.
- Chiller needs connecting.
- John to check / confirm power of chiller unit.
- •Alan to send Pete original cooling power document for comparison.
- Duncan to get guote for running flow and return along same route as de-min circuit in both plastic and stainless steel with crimped fittings.
- •Duncan can start after this shutdown end of next week.
- John to assign new chap to this work after Duncans start.
- •Current R8 infrastructure work will be in the way of new pipework installation.

Flow meters:

- •John currently trialling new flow meters with no moving parts in R6 Cost ~£500 each.
- •Flow meters on return line only.
- Ideally flow meters should measure vertical flow upwards will impact on manifold layout. Avoid rotameters.

Valves:

- •Need separate flow control valves and on/off valves.
- Ability to isolate whole manifold.
- Don't use ball valves as on ISIS RFQ manifold not fine enough flow control.
- John to forward pics of recommended flow control valve to Pete for sizing / spacing of manifold lines.

Manifolds:

- •FETS team need to define cooling zones and produce manifold layout.
- Alberto to look at manifold layout options? (after existing job is out to manufacture).
- •Extra lines in manifolds and at ends for future extensions.
- Manifolds can be made in-house (RAL) John knows a man.

What could be bought?

- Pipework for new circuit
- •Fittings + brackets etc.
- Lagging
- Some flow meters and valves plus some small fittings for manifolds (Swagelok or cheaper alternative).

General:

- David Findlay requested overhaul and improvement of ISIS cooling no particular need for FETS to comply but may help.
- •David Findlay likes to see water flowing can we have windows somewhere in line?
- Problem with pump on existing de-min circuit suspect control system. John / Duncan to advise.
- •Pete to estimate pressure drop and conductivity through various circuits.
- Pete had wrong end date for MEBT build to be confirmed.
- Cooling to be complete before end of 2013 BIG shutdown coming.
- •While we are at it are any more air supplies needed along the FETS?
- At a later date talk to John about waveguide support framework job.

Summary from first cooling meeting on Monday 6th Feb 2012

John Govans **Trevor Pike** Alberto Me Alan Duncan Couchman



London



Comparison of Results

Property	Hand estimate	ANSYS CFD Result			
Mass flow rate	0.157 kgs ⁻¹ (9.42 Lmin ⁻¹)	0.1545 kgs ⁻¹ (9.27 Lmin ⁻¹)			
Average water flow	2 ms ⁻¹	1.914 ms ⁻¹			
Maximum water flow	5 ms ⁻¹ (desired upper limit)	4.227 ms ⁻¹			
Total Pressure	0.12 Bar	0.375 Bar			
Average HTC	8650 Wm ⁻² K ⁻¹	9000 Wm ⁻² K ⁻¹			
Water temperature rise	3 °C	3 °C			

Simulation matches back-of-the-envelope calculations (again... well done ANSYS!)

Copper temperature similar to previous simulations with different flow \rightarrow Good

To do now: try a more accurate model and put in a squirt nozzle





Metals compatible with demineralised water

IMPACTS ON THE DESIGN

Metals choice



Due to distinctive <u>chemical aggressiveness</u> of demineralised water and to the <u>galvanic effect</u> anyhow present with low conductivity media, the <u>choice of metals</u> to be used into the different parts of the cooling closed loop shall be compliant with the following non exhaustive list of instructions:

- Metals **compatible** with demineralised water: Stainless steel Copper Aluminium Zinc free bronze
- Metals **non compatible** with demineralised water: Brass
 - Bronze Carbon steel
 - Galvanised steel
 - Chromate steel
- Allowed metals mixture in the same circuit Aluminium and stainless steel Copper and stainless steel
- **Mixture of metals** to be avoided in the same circuit Aluminium and copper / copper alloys

Paolo Guglielmini - TS / CV

JCOV - 11/05/2006



	Electricity	Amps	Isolation	Phase	Water (demin)			
		-					Flow	Flow
						Non	rate for	rate for
					Temp.	temp.	1C H ₂ 0	10C H ₂ 0
					controlle	controlle	temp	temp
					d	d	rise (l/m)	rise (I/m)
	kVA				kW*	kW**		
on source	16	20	}Yes, isolate	1				
on source	10	20	}Yes	3				
lon source HT	5	6	} together	3				
LEBT solenoid PSUs	30	39	Yes	3		5		7
LEBT solenoids	0					25		36
Klystron	300	390	Yes	3		175		250
Load						75		107
RFQ					75		1071	
Chopper	10	13	}Yes, isolate	1	10		143	
MEBT magnet PSUs	20	26	} together	1				
MEBT magnets						20		29
MEBTRF	50	65	Yes	3	25		357	
Beam dump						20		29
Vacuum system	20	26	}Yes, isolate	1				
Other [†]	50	65	} together	1	10	10	143	14
Chillers*	50	65	Yes	3		170		243
Total		740			100	500	1714	744
Total	501	719			120	500	1714	/14
				Water velo	city in 3"	pipe (m/2)	6.3	2.6
				Water velo	city in 4"	pipe (m/2)	3.5	1.5
assumes temp, controlled water com	es from chillers cool	ed by tower	water					

[†]diagnostics, controls, low power stuff

an

Slide 30 of 32



How much power are we trying to cool?



In total we require something like 100kW of cooling. Note that the distribution of cooling power will not be evenly spread along the length of the FETS.



MEBT cooling

